

**Minutes for  
Town of Hanson  
Board of Health Meeting  
Tuesday, March 10, 2020**

Meeting Start Time: 4:00pm

Place: Board of Health Office

Hanson Town Hall, 542 Liberty Street, Hanson, MA 02341

Having a quorum, Ms. Dias called the meeting to order at 4:02pm

Present: Ms. Dias, Mr. Perkins, Mr. Amado & Ms. Cocio

**NEW BUSINESS**

**I. New Business:**

1. Mr. Perkins made a motion to nominate Mr. Amado as the Milk Inspector, 2<sup>nd</sup> by Ms. Dias. 2-0
2. The food pantry, represented by Chris Cameron came before the Board to discuss the plastic bag by-law. The Board does not believe that the pantry falls under the by-law, so they may continue to use plastic bags. Ms. Cameron also requested a waiver for the use of the PAYT bags. The Board declined the request.
3. Camp Kiwanee event with 75 or more attendees – The camp Director, who has his serv safe, asked if they were able to have a fundraising event with delivery pizza served by the caretakers and the director and sell candy, the Board denied the request.
4. Nomination of the Animal Inspector – Mr. Perkins made a motion to nominate Ms. Shirley Savage Cavicchi as the Animal Inspector, 2<sup>nd</sup> by Ms. Dias. 2-0
5. Septic Plans for approval
  - a. **30 Fallon Point** – 5 Bedroom – Deed Restriction – Mr. Perkins made a motion to approve the plan with the following variances, 2<sup>nd</sup> by Ms. Dias, 2-0
    - i. Allow the proposed septic tank and pump chamber to be 51' from Oldham Pond (Tributary to a water supply) instead of 200' required.
    - ii. Allow the proposed SAS to be 11' from a cellar wall instead of 20' required (with impervious barrier).
    - iii. Allow the bottom of the proposed SAS to be 3.03' from soil mottling instead of the required 5' (with treatment).
    - iv. Allow the use of a sieve test to determine L.T.A.R.
    - v. Allow a 65' setback from the proposed SAS to the southerly abutters well instead of the 100' required.
    - vi. Allow the proposed SAS to be 60' from Oldham Pond, tributary to a water supply, instead of 200' required (with treatment).
    - vii. Allow the proposed SAS to be 87' from the locus well instead of the 100' required.
  - b. **57 Holly Ridge** – 3 Bedroom – Deed Restriction – Mr. Perkins made a motion to approve the plan with the following variances, 2<sup>nd</sup> by Ms. Dias, 2-0
    - i. To allow a 3.05' separation from seasonal high groundwater rather than the required 4'.
    - ii. To allow the use of a sieve analysis to determine the L.T.A.R.
  - c. **619 High Street** – 3 Bedroom – Deed Restriction – Mr. Perkins made a motion to approve the plan with the following variances, 2<sup>nd</sup> by Ms. Dias, 2-0 *pending receipt of revised plans with a deed restriction notation.*
    - i. To allow a minimum 4' separation to high groundwater instead of the required 5'.
    - ii. To allow the use of a sieve analysis to determine the L.T.A.R.

**Minutes for  
Town of Hanson  
Board of Health Meeting  
Tuesday, March 10, 2020**

**II. Adjournment**

Motion to adjourn meeting made by Mr. Perkins, 2<sup>nd</sup> by Ms. Dias 2-0. Meeting adjourned at 5:07.

---

Arlene Dias, Chairman

---

Kevin Perkins, Vice-Chairman

---

Denis O'Connell, Member