

**Minutes for
Town of Hanson
Board of Health Meeting
Tuesday, October 20, 2020**

Meeting Start Time: 4:00pm

Place: Virtual

Having a quorum, Mr. O'Connell called the meeting to order at 4:01pm

Present: Mr. O'Connell, Mr. Perkins, Ms. Dias, Mr. Amado & Ms. Cocio

NEW BUSINESS

I. New Business:

1. Approve BOH Minutes for September 22, 2020 – Mr. Perkins made a motion to approve the BOH minutes for September 22, 2020, 2nd by Ms. Dias. 3-0
2. Installer requirements – Mr. Perkins would like to change the new installer requirements, everyone should have at least 1 current license and be required to take the test. Should no licenses be available the candidate will be required to come before the Board with references and resume. If the candidate does not pass the test, no retests for 6 months. Ms. Dias made a motion to accept above changes for septic installers, 2nd by Mr. Perkins. 3-0
3. Halloween – CDC guidelines to be added to webpage.
4. Septic Plans
 - A. **376 Phillips – 3 Bedroom – Deed Restriction** – Ms. Dias made a motion to allow for the following variances, 2nd by Mr. Perkins. 3-0
 - i. To allow the use of a grain size distribution analysis to establish a design load rate where a percolation test cannot be performed due to high groundwater.
 - ii. To allow depth to groundwater is requested. A minimum of 3' separation to high groundwater will be maintained.
 - B. **11 Beckett Street – 3 Bedroom – Deed Restriction** – Ms. Dias made a motion to allow for the following variances, 2nd by Mr. Perkins – Deed Restriction Notation
 - i. To allow for a 5' separation to high groundwater in soils from the required 5' to 4' requested.
 - ii. To allow a reduction of the required number of deep holes from 2 to 1.
 - C. **125 Glenwood Place – 3 Bedroom – Deed Restriction** – Mr. Perkins made a motion to allow for the following variances, 2nd by Ms. Dias Note to be added Boots or hydraulic cement to be added on tanks with a liquid membrane. note for deed restriction
 - i. To allow a SAS to groundwater vertical separation from the required 4' to 3'.
 - ii. To allow a tank invert to groundwater vertical separation from the required 12" to the proposed 0".

II. Adjournment

Motion to adjourn meeting made by Mr. Perkins, 2nd by Ms. Dias 3-0. Meeting adjourned at 4:32.

Denis O'Connell, Chairman

Kevin Perkins, Vice-Chairman

Arlene Dias, Member